



MOBILE HOMES EQUIPPED WITH POWER SUPPLY CORD AND PLUG RATED 40 AMPS OR 50 AMPS SHALL BE CONNECTED TO OUTSIDE SERVICE EQUIPMENT THROUGH A COMPATIBLE FEMALE RECEPTACLE AND SHALL BE PROTECTED BY A CIRCUIT BREAKER OR FUSE OF EQUAL RATING.

MOBILE HOME PARKS AND GROUPS OF TRAILERS WILL BE ENGINEERED ON AN INDIVIDUAL BASIS BY COOP PER NATIONAL ELECTRIC CODE.

| NO. | REVISION | DATE |
|-----|------------------|----------|
| 2 | UPDATE | 1/13/21 |
| 1 | UPDATED PER NESC | 11/14/13 |

| |
|---------------|
| DATE: 9-21-90 |
| DRAWN BY: EAM |
| APP'D BY: KMM |

JOE WHEELER ELECTRIC MEMBERSHIP CORP.
 TRINITY, ALABAMA
 McWHORTER & FRANKLIN ENGINEERS NASHVILLE, TENNESSEE

| |
|----------------|
| SCALE: |
| SPEC NO. MH-12 |
| PAGE 2 |